

# DISTRIBUTION SYSTEM COLIFORM MONITORING REPORT

SYSTEM NAME: MARINA COAST WATER DISTRICT WATER SYSTEM

SYSTEM NUMBER: CA2710017

REPORTING PERIOD: August 2024

LABORATORY: Monterey Bay Analytical

EAP CERTIFICATE: 2386  
METHOD: SM9223B - Colliert

GROUP	DATE COLLECTED	COLLECTED BY	EMPLOYED BY	SAMPLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	Chlorine Residual
A	5-Aug.-2024	Goncalves	MCWD	13	DS - 3106 Flower Circle	Routine	Absent	Absent	1.01
	5-Aug.-2024	Goncalves	MCWD	14	DS - 3073 Zaretta Drive	Routine	Absent	Absent	0.92
	5-Aug.-2024	Goncalves	MCWD	15	DS - 3196 Melanie Road	Routine	Absent	Absent	1.00
	5-Aug.-2024	Goncalves	MCWD	16	DS - 3345 Cardoza Avenue	Routine	Absent	Absent	0.96
	5-Aug.-2024	Goncalves	MCWD	17	DS - 3271 Cove Way	Routine	Absent	Absent	0.93
	5-Aug.-2024	Goncalves	MCWD	18	DS - 314 Ardennes Circle	Routine	Absent	Absent	0.92
	5-Aug.-2024	Goncalves	MCWD	19	DS - 325 Buna Road	Routine	Absent	Absent	0.91
	5-Aug.-2024	Goncalves	MCWD	20	DS - 207 Rome Road	Routine	Absent	Absent	0.94
	5-Aug.-2024	Goncalves	MCWD	21	DS - Airport Vault	Routine	Absent	Absent	0.62
	5-Aug.-2024	Goncalves	MCWD	22	DS - 4790 Peninsula Point Drive	Routine	Absent	Absent	0.97
B	12-Aug.-2024	Goncalves	MCWD	D1	DS - 263 Grant Street	Routine	Absent	Absent	0.92
	12-Aug.-2024	Goncalves	MCWD	D2	DS - 3020 Jean Street	Routine	Absent	Absent	0.96
	12-Aug.-2024	Goncalves	MCWD	D3	DS - 266 Cosby Drive	Routine	Absent	Absent	0.93
	12-Aug.-2024	Goncalves	MCWD	D4	DS - 3180 Nihole Drive	Routine	Absent	Absent	0.90
	12-Aug.-2024	Goncalves	MCWD	D5	DS - 3203 DeForest Road	Routine	Absent	Absent	1.09
	12-Aug.-2024	Goncalves	MCWD	D6	DS - 1701 Eichleberger Court	Routine	Absent	Absent	0.94
	12-Aug.-2024	Goncalves	MCWD	D7	DS - 3071 Wilkemyer Court	Routine	Absent	Absent	0.89
	12-Aug.-2024	Goncalves	MCWD	D8	DS - 111h Street-Imjin Road	Routine	Absent	Absent	0.82
	12-Aug.-2024	Goncalves	MCWD	D9	DS - 110 Nijmegen Road	Routine	Absent	Absent	0.86
	12-Aug.-2024	Goncalves	MCWD	D10	DS - 180 Okinawa Road	Routine	Absent	Absent	0.92
C	19-Aug.-2024	Goncalves	MCWD	A1	DS - 3324 Abdy Way	Routine	Absent	Absent	1.15
	19-Aug.-2024	Goncalves	MCWD	A2	DS - 3020 King Circle	Routine	Absent	Absent	1.04
	19-Aug.-2024	Goncalves	MCWD	A3	DS - 3166 Crescent Avenue	Routine	Absent	Absent	1.09
	19-Aug.-2024	Goncalves	MCWD	A4	DS - 221 Cypress Avenue	Routine	Absent	Absent	0.99
	19-Aug.-2024	Goncalves	MCWD	A5	DS - 3106 Bayer Street	Routine	Absent	Absent	1.02
	19-Aug.-2024	Goncalves	MCWD	A6	DS - 5871 Imjin Road	Routine	Absent	Absent	0.89
	19-Aug.-2024	Goncalves	MCWD	A7	DS - 3570 3rd Street	Routine	Absent	Absent	0.81
	19-Aug.-2024	Goncalves	MCWD	A8	DS - 326 Carlanan Road	Routine	Absent	Absent	1.04
	19-Aug.-2024	Goncalves	MCWD	A9	DS - 180 Balaban Road	Routine	Absent	Absent	0.86
	19-Aug.-2024	Goncalves	MCWD	A10	DS - 5060 Fitch Middle School	Routine	Absent	Absent	0.92
D	26-Aug.-2024	Goncalves	MCWD	B1	DS - 3076 Clarke Place	Routine	Absent	Absent	0.84
	26-Aug.-2024	Goncalves	MCWD	B2	DS - 3136 Lynsott Drive	Routine	Absent	Absent	0.93
	26-Aug.-2024	Goncalves	MCWD	B3	DS - 3270 Michael Drive	Routine	Absent	Absent	0.92
	26-Aug.-2024	Goncalves	MCWD	B4	DS - 3100 Everett Circle	Routine	Absent	Absent	0.98
	26-Aug.-2024	Goncalves	MCWD	B5	DS - 300 Quebeca del Mar Road	Routine	Absent	Absent	0.86
	26-Aug.-2024	Goncalves	MCWD	B6	DS - 3438 Spotsylvania Court	Routine	Absent	Absent	0.93
	26-Aug.-2024	Goncalves	MCWD	B7	DS - 6th Avenue 53	Routine	Absent	Absent	1.02
	26-Aug.-2024	Goncalves	MCWD	B8	DS - 4235 Gidding Road	Routine	Absent	Absent	0.96
	26-Aug.-2024	Goncalves	MCWD	B9	DS - 1830 Cassino Road	Routine	Absent	Absent	0.93
	26-Aug.-2024	Goncalves	MCWD	B10	DS - Seaside High School	Routine	Absent	Absent	0.98

Marina Coast Water District-WSSSP, Dec. 5, 2006, Amended November 30, 2012, Amended September 21, 2021. Group sampling is on a weekly rotation.

Joe Pineda  
Operations & Maintenance Supervisor

Sent 4/2024  
Date of Report